



Department of Natural Resources
Air Quality Bureau
7900 Hickman Road, Suite 1
Urbandale, IA 50322
515-242-5100

ASBESTOS REQUIREMENTS CHECKLIST

Facility Name _____

Address _____

City _____

Owner/Operator _____

Date _____

- ☐ Suspect materials have been found for which there is no information about the asbestos content. It appears that the inspection for asbestos-containing materials may not have been thorough. Prior to continuing, you must have the facility reinspected for asbestos-containing materials. You must provide the Iowa Department of Natural Resources with a copy of the analysis results.
- ☐ Debris, that resembles the regulated asbestos-containing material being removed, has been found in an area of the project where it appears that the abatement process has been completed and the contractor has moved on to other areas or is collecting air clearance samples. This debris is in a dry condition. You are required to immediately reclean this area.
- ☐ Regulated asbestos-containing material that is being abated in containment has been found in a dry condition. You are required to immediately wet this material and seal it in a leak-tight container. Further you are to take steps to make sure this material remains wet until it is sealed in a leak-tight container.
- ☐ Regulated asbestos-containing material is being removed in a dry condition. This material is to be wetted immediately and sealed in a leak-tight container. You are required to take steps to wet the material prior to removal and keep it wet during the removal operation.
- ☐ You are demolishing a facility. Suspect materials are present in the demolition debris. You are required to stop the demolition and have the suspect material tested for asbestos content. If the material is determined to be asbestos-containing material, you are required to obtain the services of an asbestos abatement contractor, and all of the demolition debris must be taken to the landfill as asbestos-containing waste.

The above checked items have been explained to me and I understand what I must do to correct the present problem. I have been given a copy of the asbestos regulations. I understand that this is not an admission of guilt. I understand that DNR may initiate legal action based on their findings.

Owner/operator signature

Inspector signature

- ☐ No one is present at the site and I will initiate a telephone conversation with the owner or operator.

Inspector's initials: _____

Date called: _____